

Modified reissue

Report of the classification of the reaction to fire performance

No. 230010043-3

issued 23 June 2020

English version

Sponsor

BASF SE
Carl-Bosch-Str. 38

67056 Ludwigshafen
DEUTSCHLAND

Order

Classification of the reaction to fire behaviour according to DIN EN 13501-1

Date of order:

25 November 2014 and 28 April 2020

Name of the classified building product:

Flexible foam boards „Basotect B“ with thicknesses from 5 mm up to 15 mm

This report determines the classification of the above-mentioned building product in accordance with the procedure given in DIN EN 13501-1 „Fire classification of construction products and building elements – part 1: classification using data from reaction to fire tests; German version EN 13501-1: 2007+A1:2009“, edition January 2010.

Publishing and copying of classification reports without permission of MPA NRW is only allowed without any changes of the content and the form of the reports.

A shortened reproduction of a certification report needs the permission of MPA NRW.

This classification report consists of 4 pages.

1. Description of the building product

Flexible melamine resin foam boards named „Basotect B“.

Thickness: 5 mm - 15 mm

Density: approx. 7.5 kg/m³

Colour: white

2. Test reports and test results which form the basis of the classification

2.1 Test reports

Name of the laboratory	Sponsor	Number of the test report	Test method
MPA NRW	BASF SE Carl-Bosch-Str. 38 67056 Ludwigshafen GERMANY	230010043-1 of 02 June 2015	DIN EN 13823
MPA NRW	BASF SE Carl-Bosch-Str. 38 67056 Ludwigshafen GERMANY	230010043-2 of 02 June 2015	DIN EN ISO 11925-2

Indication 1: This modified reissue of the classification report is based on indicative tests, the results of which are documented in the following reports.

Name of the laboratory	Sponsor	Number of the test report	Test method
MPA NRW	BASF SE Carl-Bosch-Str. 38 67056 Ludwigshafen GERMANY	231000815-1 of 23 June 2020	DIN EN 13823
MPA NRW	BASF SE Carl-Bosch-Str. 38 67056 Ludwigshafen GERMANY	231000815-4 of 23 June 2020	DIN EN ISO 11925-2

Indication 2: The results of these indicative tests confirm the classification of the product described in section 1.

2.2 Test results

Test method	Number of tests	Parameter	Test results	
			Continuous parameter average values	Discrete parameter
DIN EN 13823	6	FIGRA _{0,2} (W/s)	2.3	--
		FIGRA _{0,4} (W/s)	2.3	--
		THR _{600s} (MJ)	1.0	yes
		LFS < outer edge	--	--
		SMOGR _A (m ² /s)	2.0	--
		TSP _{600s} (m ²)	46.0	--
		burning droplets/particles (s)	0	--

Test method	Number of tests	Parameter	Test results	
			Continuous parameter average values	Discrete parameter
DIN EN ISO 11925-2	12 x K and 18 x F	F _S ≤ 150 mm Burning droplets / particles	--	yes
			--	no

Remark: K = tested with flames exposed to the edge, F = tested with flames exposed to the surface

Indication: The classification is based on test reports nos 230010043-1 and 230010043-2 dated 02 June 2015.

3. Classification and direct field of application

3.1 Reference

The classification was carried out in accordance with the clauses 11. and 14.1 of the standard DIN EN 13501-1:2010.

3.2 Classification

The tested material in relation to its fire behaviour is classified as: **B**

The additional classification regarding the smoke production is: **s1**

The additional classification regarding burning droplets / particles is: **d0**

This results in a classification of the reaction to fire behaviour of the tested material:

Fire behaviour	Smoke production	Burning droplets / particles
B	s1	d0

i.e. **B – s1, d0**

3.3 Field of application of the product

The classification is solely valid for the product described in clause 1 for the following fields of application:


- Directly laid and mechanically fixed onto substrates classified as A1 and A2-s1,d0 with a density of at least 653 kg/m³ and a thickness of at least 9 mm.

4. Restrictions

This classification report does not replace any type approval or certification of the product.

This classification report written in English language is issued additionally to the report written in German language with the same report number. In case of doubt the German version is valid solely. This classification report is only valid in combination with the German version of the report.

Erwitte, 23 June 2020



Dipl.-Ing. Rademacher
Head of the testing body



Date of issue of this English version: 23 June 2020